



PIMPRI CHINCHWAD MUNICIPAL CORPORATION, PIMPRI -
FIRE DEPARTMENT

File No - 278

OW. No. Fire/5/BV/WS/278/2024

Date - 06/06/2024

FIRE SAFETY CERTIFICATE

Token No - 103324250003027

Token Dt. - 21/05/2024

School Name - K.V. Tilwani Educational Foundation's, Academic Heights Public School

Address - Gat. No. 1660/2 Bag Wasti, Patil Nagar, Chikhali, Pune - 412114

Has applied for Fire Safety Certificate

The Fire Officer has visited the school inspected the Fire Protection System installed at site and as per his technical remarks this NOC is being issued subject to compliance of following conditions.

- 1) The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
- 2) The fire extinguishers handling and operational training to be imparted to the teaching/non-teaching/security staff of the school.
- 3) You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-'B' Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
- 4) You will keep all the Static Water Tanks full for any fire emergency.
- 5) Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustible material
- 7) "No Smoking Boards" "Emergency Exit" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
- 8) You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
- 9) You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
- 10) This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 11) You are not permitted to construct the school building's remaining floors in the school working hours.
- 12) All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- 13) This School Operational (Utility) Fire NOC is issued with respect to the Final Fire NOC No. Fire/5J/WS/1071/2023, Dt. 18/12/2013 of Fire Dept. PCMC for only GP+02 Floor, Heights -10.50 Mtrs, with Gross Built up Area - 1588.79 mtrs. And the terms and condition must be strictly fulfilled mentioned in above mentioned final fire NOC.
- 14) This Fire NOC is valid up to **Dt. 31 March 2025** only and renewal of these NOC should be done every year before above mentioned date.

Sub Fire Officer

Pimpri Chinchwad Municipal Corporation
Pimpri-18

To,

The Principal

K.V. Tilwani Educational Foundation's, Academic Heights Public School

Gat. No. 1660/2 Bag Wasti, Patil Nagar, Chikhali, Pune - 412114

No	Particulars	Fees Paid Rs.	Receipt No & Date
1	Paid For CFC	500/-	R.No. 303324250005068 Dt. 21/05/2024
2	Paid For Certificate	1,5600/-	R.No. 303324250006683 Dt. 06/06/2024

Principal

Secretary/Manager