



*** File No – OW. No. Fire/CG/WS/E-52/2026

Date 25/08/2026

FIRE SAFETY CERTIFICATE

Online Paid Receipt no.TRFBS1117, Dt.25/08/2026.

Online Application No.20261675 , Dt.11/08/2026.

School Name – K V Tilwani Educational Foundation Academic Heights Public School

Address – Survey No.1660/2, Bag Vasti, Patil Nagar, Chikhali, Pune-412144



Has applied for Fire Safety Certificate

The Fire Officer has visited the school inspected the Fire Protection System installed at site and as per his technical remarks this Fire Safety Certificate is being issued subject to compliance of following conditions.

- 1)The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
- 2)The fire extinguishers handling and operational training to be imparted to the teaching/non-teaching/security staff of the school.
- 3)You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-‘B’ Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this Fire Safety Certificate shall be treated as cancelled.
- 4)You will keep all the Static Water Tanks full for any fire emergency.
- 5)Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6)You will keep all passages and corridors free from any obstructions and combustible material
- 7)“No Smoking Boards”, “Emergency Exit” “Assembly Area” and “Emergency Contact Numbers Boards” of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
- 8)You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
- 9)You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
- 10)This Fire Safety Certificate is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 11)You are not permitted to construct the school building’s remaining floors in the school working hours.
- 12)All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- 13)This Fire Safety Certificate is valid up to **Dt. 24 August 2027** only and renewal of these Fire Safety Certificate should be done every year before above mentioned date.

Sub Officer (Fire)

Pimpri Chinchwad Municipal Corporation

Pimpri-18

To,

The Principal

K V Tilwani Educational Foundation Academic Heights Public School

Survey No.1660/2, Bag Vasti, Patil Nagar, Chikhali, Pune-412144