

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

No WS/LAB/519/2024

Date 27/04/2024

Date of Receipt 28/04/2024

Date of Examination 28/04/2024

NAME - अकेश/मिा पीडर पाडलक अकुल

ADDRESS - अा नं 1660 पाडलनगर, पिाडी

SOURCE - PCMC Water

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	0.48 NTU		
2	pH	6.5 to 8.5	7.12		
3	Total Hardness (as CaCO ₃)	200 mg/lit	64 mg/lit		
4	Chloride	250 mg/lit	26 mg/lit		
5	Calcium	75 mg/lit	14.42 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/583/2026.

Date - 29 / 07 / 2026.

DATE OF EXAMINATION - 28 / 07 / 2026

NAME - अकॅडमिक हाईट्स पब्लिक स्कूल.

ADDRESS - गट नं. 1660, पार्श्वलनगर, चिखली.

SOURCE - PCMC Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample.	0.4 ppm	0/100ml	-	Potable.
2					 CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nagdi, Pune 44
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY